FM 40432

ILE MIDLANDS LTD
Technical Support Department
Wanlip Road, Syston, Leicester, LE7 1PD.
Telephone: 0116 2690900   Fax: 0116 2690939

Password entry and i/o setup

1)   To enable access to password level 1 parameters an ENGINEER PRESENT needs to be registered on Skycom. This can be done by pressing and holding the MODE button then with the MODE button still pressed also press the ENTER button. The screen will then show an ENGINEER PRESENT has been logged.

2)   In order to access password level 2 protected parameters a password needs to be entered this password is generated from the ILE contract number. This password can be obtained from ILE when required.

3)   To step through the Skycom parameter menu press the menu button on the keypad and a black bar (the cursor) will be across the top menu item 'EVENT HISTORY'. Scroll through the menu headings using the down arrow until the required menu is reached.

EVENT HISTORY
EVENT TRACE BUFFER
TRACE SETUP
ENTER CALLS
LIFT VIEWER
GROUP / WAITING TIMES
INPUT OUTPUT VIEWER
JOB DETAILS
SYSTEM DETAILS
MODIFIED PARAMETERS
GENERAL PARAMETERS
GENERAL TIMES
DOOR SETUP
DOOR TIMES
TRAVEL SETUP
HOMING SETUP
IO SETUP
OUT OF SERVICE SETUP
HYDRAULIC SETUP
ANTI NUISANCE SETUP
FIRE CONTROL SETUP
SPECIAL SERVICE SETUP
SPECIAL SERVICE TIMES
ETA PARAMETERS
EXTERNAL DEVICES
PX DELAYS SETUP
PREVIOUS PX SETUP
FLOOR SPEED SETUP

FLOOR CALLS/ALLOCS
FLOOR DATA SETUP
ENGINEER SETUP
GROUP SETUP
M.G. SEQUENTIAL START
ADVANCING SELECTOR
DATE TIME SETUP
GENERAL INFORMATION
PARAMETER CONTROL

4)   To enter a password step down to PARAMETER CONTROL and then press the ENTER button. This takes you into the sub menu and the cursor will be highlighting the first item PASSWORD ENTRY this needs to be selected by pressing the enter button again.

5)   A set of brackets will appear with a cursor pointing over the first space where a character needs to be entered.

PASSWORD ENTRY
[↓   ]
[   ]

The first character is selected using the up and down arrows and then the right arrow is pressed to move the cursor to the next character. When the full password is on the screen in between the brackets the enter button is pressed to enable the password. The screen will then flash up with the password level and OK.

6)   To modify or add i/o on Skycom the i/o setup menu needs to be selected this is done by pressing the menu button and then scrolling down through the menu to IO SETUP and then press the enter button.

7)   Then from within the sub menu scroll down to the slot with the card that needs changing and then press the enter button. The input or outputs will then be listed if there are inputs and outputs on the card by pressing the right arrow you can toggle between the two.

8)   A cursor (thick minus symbol) will be alongside the top input or output indicating this is the selected input or output. To scroll through which input or output is to be changed press and hold the MODE button then with the MODE button still pressed also press the UP ARROW button and the cursor will move up the screen jumping from the top input or output back down to the bottom.

9)   When the i/o to be changed has the cursor alongside it the UP and DOWN arrows can be used to scroll through the available i/o. When the input or output required is displayed the ENTER button is pressed and the screen will flash up PARAMETER UPDATED.